

# Rush Creek Task Force (CCPG)

April 27, 2017

## Meeting Notes

### 1. Introduction

- ❖ See Attendance list

### 2. Anti-trust Reminder

- ❖ Patrick reviewed the anti-trust guidelines with the group. The guidelines are attached to the meeting agenda.

### 3. Approve Meeting Notes

#### a. March 29, 2017 Meeting

- ❖ Patrick sent the draft notes on April 12, 2017
- ❖ Some clarifications were received from Lisa Hickey
- ❖ No further corrections were provided at this meeting.
- ❖ Motion:
  - PSCo (Tom Green) moved to approve the March 29, 2017 meeting notes, with the clarifications provided by Ms. Hickey.
  - Tri-State (Ryan Hubbard) seconded the motion.
- ❖ Discussion:
  - None
- ❖ Vote:
  - No objections were noted.
  - March 29, 2107 meeting notes were approved.

### 4. Action Item Review

- ❖ Reviewed the action items from the February 22, 2017 meeting:

Item	Action	Status
1	Draft Benefits Language	Ongoing
2	Light load powerflow studies	Discuss Today
3	Transient Stability studies	Ongoing
4	Modify Results Spreadsheet	Complete – Discuss Today
5	Cost Estimates	Ongoing

- ❖ Related to costs, PSCo evaluated line mileages between Rush Creek I and Daniels Park, and a potential substation on the Comanche – Daniels Park lines.
  - The line estimation showed approximately 46 miles from Rush Creek I to a new switching station on the Comanche – Daniels Park 345 kV lines. The new switching station is approximately 21 miles south of Daniels Park
  - See photo in Attachment A

## 5. Review of Study Results

### a. Heavy Summer

- ❖ PSCo reviewed the updated study results
- ❖ The focus was on alternatives that were limited by the Leetsdale – Monroe 115 kV underground line loading, but also on Pawnee - Daniels
- ❖ Noted that upgrades to the limited lines were not specifically modeled when moved to the next limiting element.

### b. Light Spring

- ❖ PSCo reviewed the light spring study results
- ❖ The results showed similar injection results as the heavy summer except for the Benchmark case where Pawnee-Story 230 kV line was as a limiter.
- ❖ It appeared there was too much generation on PSCo's system necessary to meet PSCo's load obligations.
- ❖ Attachment B summarizes the Heavy Summer and Light Spring results.

## 6. Stakeholder Comments

- ❖ Mark Detsky advocated for more alternatives for the task force to analyze which would increase injection capabilities in eastern Colorado. Mark suggested expanding some alternatives with by adding a 345 kV line from Big Sandy to Story.
- ❖ The RCTF agreed to study two additional alternatives:
  - Alt 5a: RCI to Big Sandy to Story, RCII to Burlington
  - Alt 5b: RCI to Big Sandy to Story, RCII to Burlington, RCI to Daniels Park
  - Per Chris Neil's request, the RCTF agreed to run one sensitivity analysis with a 345 kV connection from Pawnee to Story to ensure the connection does not overload any other lines in the area.

## 7. Action Items

Item	Action	Resp
1	Draft Benefits Language	PSCo
2	Update power flow results with new alternatives	PSCo
3	Transient stability analysis	PSCo
4	Cost estimates	PSCo
5	Summarize results with narrative	PSCo

## 8. Next Meeting

- ❖ May 25, 2017; 1:00 PM


## 9. Attendees List

Rush Creek Task Force				
LastName	FirstName	Company/Org	Email	4/27/2017
Arnold	Paul	Power Engineers	paul.arnold@powereng.com	
Audette Muniz	Jessie	Apex Clean Energy	jessie.audette@apexcleanenergy.com	Phone
Breihan	David	IREA	dbreihan@irea.coop	
Brownrigg	Jeremy	PRPa	brownrigg@prpa.org	
Caldara	Paul	Colorado PUC	paul.caldara@state.co.us	
Caldwell	Scott	Alterra Power USA Corp	scaldwell@alterrapower.ca	Phone
Carlson	Shawn	Basin	scarlson@bepc.com	Phone
Cichosz	Jon	Black Hills	jon.cichosz@blackhillscorp.com	Phone
Corrigan	Patrick	Xcel Energy	patrick.m.corrigan@xcelenergy.com	Patrick
Crawford	Rich	Midwest Wind Resources	midwestwind1@gmail.com	
Crosby	Missy	Xcel Energy	Melissa.M.Crosby@xcelenergy.com	Phone
Dang	Dang	S-Power	ddang@spower.com	
Degutis	Erlin	Xcel Energy	Erlin.A.Degutis@xcelenergy.com	
Detsky	Mark	Dietze & Davis	mdetsky@dietzedavis.com	M D
Easton	Robert	Western	aeaston@wapa.gov	
Fauerstein	Pam	IREA	PFauerstein@irea.Coop	
Foltz	Adam	S-Power	afoltz@spower.com	
Gearhart	Roy	Western	rgearhar@wapa.gov	
Ghoshal	Orijit	Invenergy	OGhoshal@invenergyllc.com	
Green	Tom	Xcel Energy	thomas.green@xcelenergy.com	Tom
Greene	Lynn	Lucky Corridor	lynn@luckycorridor.com	
Hickey	Lisa	Interwest Energy Alliance	LisaHickey@newlawgroup.com	ETA
Hirning	Jim	Western	Hirning@WAPA.GOV	
Hubbard	Ryan	Tri-State	rhubbard@tristateqt.org	Phone
Jammalamadaka	SwaraJ	Apex Clean Energy	swara.jammalamadaka@apexcleanenergy.com	
Jurgemeyer	Mark	IREA	MJurgemeyer@irea.Coop	
Leuchtmann	Greg	Invenergy	GLEuchtmann@inveneryllc.com	
Lovejoy	Susan	CSU	slovejoy@csu.org	
Mirzayi	Betty	Xcel Energy	betty.mirzayi@xcelenergy.com	37KJ
Neil	Chris	Office of Consumer Council	chris.neil@state.co.us	and
Paoletti	Connie	Xcel Energy	connie.paoletti@xcelenergy.com	
Parisch	Puneet	Buckyball Systems	parisch@buckyballsystems.com	
Peters	Nathan	Western	npeters@WAPA.GOV	Phone
Pink	Chris	Tri-State	cpink@tristateqt.org	Phone
Rein	Mike	Xcel Energy	Michael.A.Rein@xcelenergy.com	Phone
Singh	Hari	Xcel Energy	Hari.singh@xcelenergy.com	
Stegall	Lindsey	Colorado Energy Office	lindsey.stegall@state.co.us	
Sydnor	Marc	Apex Clean Energy	marc.sydnor@apexcleanenergy.com	
Tauber	Sage	Xcel Energy	Tauber, Sage (sage.tauber@xcelenergy.com)	Sage
Taylor	Joe	Xcel Energy	joseph.c.taylor@xcelenergy.com	
Taylor	Blane	Tri-State	btaylor@tristateqt.org	
Wedewer	Lindsey	Colorado Energy Office	lindsey.wedewer@state.co.us	
Wandling	Warren	Wandling Consulting	w.l.wandling@q.com	
Wingen	Wes	Black Hills	Wes.Wingen@blackhillscorp.com	Phone
Worley	Chris	Colorado Energy Office	chris.worley@state.co.us	

Atkinson Sean IREA

Phone

10. Attachment A – Line length estimations for alternatives into Daniels Park



11. Attachment B – Alternative Analysis Summary

Rush Creek Task Force

Alternative Analysis 4/27/2017

Power Flow Results - Heavy Summer  
2026

Alternative	Alternative Description	Incremental Injection Capability (MW)	Total Injection Capability (MW)	Limiting Element	Owner	Limiting Rating	Limiting Contingency
Alt 0	Benchmark	550	1150	Leetsdale-Monroe 230 kV UG	PSCo	398 MVA	Daniels Park-Arapahoe 230 kV
		850	1450	Pawnee-Story 230 kV	PSCo	576 MVA	Missile Site-Smoky Hill 345 kV
Alt 1	RCII - Burlington	100	700	Burlington-Bonny Creek 115 kV	TSGT	145 MVA	Missile Site-RCI 345 kV
		200	800	Burlington-Big Sandy 230 kV	TSGT	274 MVA	
		250	850	Wray-N Yuma 230 kV	TSGT	287 MVA	
Alt 2	RCI - Big Sandy	100	700	Big Sandy-Last Chance 115 kV	WAPA	109 MVA	Missile Site-RCI 345 kV
		250	850	Last Chance-Beaver Creek 115 kV	WAPA	109 MVA	
		250	850	Burlington-Big Sandy 230 kV	TSGT	274 MVA	
Alt 3	RCII - Limon gen	-250	350	Missile Site-Limon I 345 kV	Other	810 MVA	Missile Site-RCI 345 kV
Alt 4	Missile - RCI - RCII #2	550	1150	Leetsdale-Monroe 230 kV UG	PSCo	398 MVA	Daniels Park-Arapahoe 230 kV
		850	1450	Pawnee-Story 230 kV	PSCo	576 MVA	Missile Site-Smoky Hill 345 kV
Alt 5	RCII - Burlington, RCI-Big Sandy	350	950	Big Sandy-Last Chance 115 kV	WAPA	109 MVA	Missile Site-RCI 345 kV
		500	1100	Burlington-Bonny Creek 115 kV	TSGT	145 MVA	

		550	1150	Lincoln-Midway 230 kV	TSGT	637 MVA	
Alt 6	RCII - Burlington, RCI-Limon gen	-100	500	Missile Site-Limon I 345 kV	Other	810 MVA	Missile Site-RCI 345 kV
Alt 7	RCII - Burlington, RCII-Limon gen	-100	500	Missile Site-Limon I 345 kV	Other	810 MVA	Missile Site-RCI 345 kV
Alt 8	RCI - Daniels Park, RCII-Burlington	550	1150	Leetsdale-Monroe 230 kV UG	PSCo	398 MVA	Daniels Park-Arapahoe 230 kV
		750	1350	N Yuma-Red Willow 115 kV	TSGT	79 MVA	Wray-Sandhill 115 kV
Alt 9	RCI - Daniels Park, RCI-RCII	550	1150	Leetsdale-Monroe 230 kV UG	PSCo	398 MVA	Daniels Park-Arapahoe 230 kV
		750	1350	Daniels Park-Santa Fe 230 kV	PSCo	319 MVA	Greenwood-Monaco 230 kV
Alt 9a	RCI - Daniels Park, RCI-RCII, Waterton Loop	600	1200	Leetsdale-Monroe 230 kV UG	PSCo	398 MVA	Daniels Park-Arapahoe 230 kV
		850	1450	Daniels Park-Santa Fe 230 kV	PSCo	319 MVA	Greenwood-Monaco 230 kV

## Power Flow Results - Light Spring 2026

Alternative	Alternative Description	Incremental Injection Capability (MW)	Total Injection Capability (MW)	Limiting Element	Owner	Limiting Rating	Limiting Contingency
Alt 0	Benchmark	250	850	Pawnee-Story 230 kV	PSCo	576 MVA	Missile Site-Smoky Hill 345 kV
		750	1350	Leetsdale-Monroe 230 kV UG	PSCo	398 MVA	Daniels Park-Arapahoe 230 kV
Alt 1	RCII - Burlington	150	750	Burlington-Bonny Creek 115 kV	TSGT	145 MVA	Missile Site-RCI 345 kV
		200	800	Burlington-Big Sandy 230 kV	TSGT	274 MVA	
		200	800	Bonny Creek-South Fork 115 kV	TSGT	147 MVA	
Alt 2	RCI - Big Sandy	100	700	Big Sandy-Last Chance 115 kV	WAPA	109 MVA	Missile Site-RCI 345 kV
		150	750	Last Chance-Beaver Creek 115 kV	WAPA	109 MVA	
		300	900	Burlington-Big Sandy 230 kV	TSGT	274 MVA	
Alt 3	RCII - Limon gen	-250	350	Missile Site-Limon I 345 kV	Other	810 MVA	Missile Site-RCI 345 kV
Alt 4	Missile - RCI - RCII #2	250	850	Pawnee-Story	PSCo	576 MVA	Missile Site-Smoky Hill 345 kV
		750	1350	Leetsdale-Monroe 230 kV UG	PSCo	398 MVA	Daniels Park-Arapahoe 230 kV

Alt 5	RCII - Burlington, RCI-Big Sandy	250	850	Last Chance-Beaver Creek 115 kV	WAPA	109 MVA	Missile Site-RCI 345 kV
		300	900	Big Sandy-Last Chance 115 kV	WAPA	109 MVA	
		550	1150	Lincoln-Midway 230 kV	TSGT	637 MVA	
Alt 6	RCII - Burlington, RCI-Limon gen	-100	500	Missile Site-Limon I 345 kV	Other	810 MVA	Missile Site-RCI 345 kV
Alt 7	RCII - Burlington, RCII-Limon gen	-100	500	Missile Site-Limon I 345 kV	Other	810 MVA	Missile Site-RCI 345 kV
Alt 8	RCI - Daniels Park, RCII-Burlington	650	1250	Leetsdale-Monroe 230 kV UG	PSCo	398 MVA	Daniels Park-Arapahoe 230 kV
		850	1450	Pawnee-Story 230 kV	PSCo	576 MVA	Missile Site-Smoky Hill 345 kV
Alt 9	RCI - Daniels Park, RCI-RCII	600	1200	Leetsdale-Monroe 230 kV UG	PSCo	398 MVA	Daniels Park-Arapahoe 230 kV
		600	1200	Pawnee-Story 230 kV	PSCo	576 MVA	Missile Site-Smoky Hill 345 kV
Alt 9a	RCI - Daniels Park, RCI-RCII, Waterton Loop	650	1250	Pawnee-Story 230 kV	PSCo	576 MVA	Missile Site-Smoky Hill 345 kV
		700	1300	Leetsdale-Monroe 230 kV UG	PSCo	398 MVA	Daniels Park-Arapahoe 230 kV