

Colorado Coordinated Planning Group Colorado Energy Plan Task Force



Public Service Company of Colorado
March 1, 2019

Agenda

- Introductions
- Antitrust Reminder
- CEP/ERP Update
- Study Update
 - Voltage Control
 - Network Upgrades
- Schedule
- Next Steps

Antitrust Reminder

It should be the policy and practice (Policy) of the parties participating in the Colorado Coordinated Planning Group to obey the antitrust laws and avoid all conduct that unreasonably restrains competition. Under this Policy, participants should avoid any conduct or behavior that violates, or that might appear to violate, the antitrust laws. Among other things, the antitrust laws forbid any agreement between or among competitors regarding prices, availability of service, product design, terms of sale, division of markets, allocation of customers or any other activity that unreasonably restrains competition.

ERP/CEP Update

Background

- **PSCo 2016 Electric Resource Plan (ERP)**
 - ▶ Filed May 2016
- **PSCo Colorado Energy Plan (CEP)**
 - ▶ Filed August 2017
- **120 Day Report**
 - ▶ Filed June 2018
- **PUC Approval of CEP Portfolio (CEPP)**
 - ▶ Sep 2018

Preferred CEP Portfolio


Table 9 - Preferred CEPP Projects

Bid ID	Project Name	Technology	MW	Ownership	In-Service
X645	[REDACTED]	Solar w/ Storage	250/125	IPP	2023
X647	[REDACTED]	Solar w/ Storage	200/100	IPP	2023
X427	[REDACTED]	Solar w/ Storage	110/50	IPP	2023
S430	[REDACTED]	Solar	75	IPP	2023
S085	[REDACTED]	Solar	72	IPP	2023
W192	[REDACTED]	Wind	500	Own	2021
W602	[REDACTED]	Wind	300	IPP	2021
W090	[REDACTED]	Wind	169	IPP	2021
W301	[REDACTED]	Wind (repower)	162	IPP	2019
G215	[REDACTED]	Gas (existing)	301	Own	2022
G065	[REDACTED]	Gas (existing)	82	Own	2022

Note: In-Service refers to the first summer the unit is available.

CEPP Map

Figure 5 - Preferred CEPP Generation Locations



CPCN Activity

➤ Wind

➤ Shortgrass Switching Station

▶ Filed: Dec 5, 2018

▶ Granted: Feb 14, 2019

➤ Cheyenne Ridge Project

▶ Filed: Dec 21, 2018

▶ Status: On-going

Study Update



CEPP Planning Activities

- **Gen-tie Reliability**
 - **Voltage Control**

- **Transmission Plan**
 - **(Network Upgrades)**

- **CPCN Participation**

Gen-Tie Reliability Studies

Gen-tie Concerns

➤ Transient

➤ Need to Maintain Transient Stability

➤ Loss of Gen-tie is Most Severe Single Contingency

➤ Loss of other Network Elements

➤ Voltage

➤ Low Gen-tie Generation → Potential High Voltage

➤ High Gen-tie Generation → Potential Low Voltage

➤ Wind Facility Power Factor Considerations

➤ Static vs. Dynamic Mitigation

➤ Network Upgrades

▶ High Renewable Penetration → Potential Thermal Overloads

Transient Studies

Transient Stability Studies

1. Rush Creek Task Force

- ▶ Report Issued 2017
- ▶ Benchmark Modeled Planned Gen-tie Configuration
- ▶ Studied Loss of Gen-tie AND 1600 MW Generation
- ▶ Conclusion: SYSTEM STABLE

2. Ultra High Penetration (UHP)

- ▶ Internal Study
- ▶ Reduced Conventional Generation in PSCo BA
- ▶ Reduced Conventional Gen in Neighboring BA
 - Craig, Hayden, LRS, CSU
- ▶ Conclusion: Need 1000-1200 MW of Conventional Gen

3. Mitsubishi

- ▶ “Frequency Excursion Analysis”
- ▶ Studied Loss of Gen-tie AND 1400 MW Generation
- ▶ Conclusion: SYSTEM STABLE

Voltage Studies

CEPP Dispatch Assumptions

➤ **Coal:**

- **Pawnee @ min**
- **Comanche @ max**

➤ **Gas:**

- **Fountain Valley 50%**
- **Manchief Off**
- **Metro Gas Used for Balance (Low)**
 - ▶ **Note – Maintain Gen @ FSV & Cher 4**

➤ **Wind:**

- **Missile/Pawnee (NE System) @ 100%,**
- **Other Wind @ 80%**

Voltage (Reactive) Results

➤ Low Gen

- 60 MVARs Shunt Reactance Recommended
 - ▶ Locate @ Shortgrass

➤ High Gen

- 570 MVARs Shunt Capacitance Recommended
 - ▶ Pronghorn 345kV: 90 MVAR
 - ▶ Missile Site 345 kV: 250 MVAR
 - ▶ Harvest Mile 345 kV: 115 MVAR
 - ▶ Daniels Park 345 kV: 115 MVAR

➤ Dynamic


- +/- 50 MVAR SVC Recommended
 - ▶ Locate @ Pronghorn

Network Upgrade Studies

Network Upgrade Studies

- Objective:
 - ▶ Accommodate CEPP
 - ▶ Develop Plan for Denver-metro System
- Methodology
 - ▶ Use System-wide Dispatch:
 - Remove Comanche 1 & 2
 - Model CEPP Generation at 100% Nameplate
 - Model Existing / Planned Wind at 80% Nameplate
 - Model Existing / Planned Solar at 85% Nameplate
 - Balance by Reducing Gas Fleet

map



Recommended Metro Upgrades


➤ **Must do:**

- Upgrade Leetsdale-Monaco 230 kV line
- Replace limiting substation equipment Greenwood-Monaco
- Replace limiting substation equipment Daniels Park-Greenwood
- Cost Relatively Minor (\$1-2 million)


➤ **Alternatives:**

- **Alt 1: New Greenwood-Arapahoe-Denver Terminal 230 kV Line**
- **Alt 2: Rebuild or Replace:**
 - ▶ Greenwood – Monaco 230 kV
 - ▶ Leetsdale – Monaco 230 kV
 - ▶ Leetsdale – Monroe 230 kV
 - ▶ Smoky Hill – Buckley – Tollgate 230 kV
- **Alt 3: Smoky Hill – Cherokee 230 kV Conversion**

Network Upgrade Alternatives Map




Base Case




Must Do

FAC-008 projects to remove sub limitations and rebuild overhead

Leetsdale-Monaco




Alternative 1 - Recommended




Alternative 2

Alt 2 – replace overloaded with higher rating conductors



Alternative 3

Alt 3 – Smoky Hill – Cherokee 230 kV Conversion



Next Steps

- **Voltage Control**
 - **Fine Tune Recommendations**
 - **Cost Estimates / Schedules**
 - **Study Report**
 - **Notify Stakeholders & Commission**

- **Network Upgrades**
 - **Cost Estimates / Schedules**
 - **Determine Final Recommendation**
 - **Study Report**
 - **Notify Stakeholders & Commission**
 - **File CPCN**

Resources

➤ Links:

➤ **CCPG**

- ▶ <http://regplanning.westconnect.com/ccpg.htm>

➤ **CEPTF**

- ▶ http://regplanning.westconnect.com/ccpg_ceptf.htm

➤ **ERP / CEP Information**

- ▶ https://www.xcelenergy.com/company/rates_and_regulations/resource_plans

➤ Email:

➤ **Tom Green:**

- ▶ thomas.green@xcelenergy.com



QUESTIONS