



# **WESTCONNECT REGIONAL TRANSMISSION PLANNING**

2018-19 PLANNING CYCLE

SCENARIO ASSESSMENT REPORT

APPROVED BY WESTCONNECT PLANNING MANAGEMENT COMMITTEE ON

JUNE 19, 2019

UPDATED JULY 28, 2021 TO REDACT NON-PUBLIC INFORMATION

(CONTACT [ADMIN@WESTCONNECT.COM](mailto:ADMIN@WESTCONNECT.COM) TO REQUEST NON-REDACTED VERSION)

---

# Contents

1	<b>1.0</b>	<b>Background &amp; Purpose .....</b>	<b>3</b>
2	<b>2.0</b>	<b>Study Scope.....</b>	<b>3</b>
3	<b>3.0</b>	<b>Load Stress Scenario .....</b>	<b>5</b>
4	3.1	Assumptions, Modeling and Study Techniques .....	5
5	3.2	Study Results.....	6
6	3.3	Summary of Findings .....	6
7	<b>4.0</b>	<b>CAISO Export Stress Scenario.....</b>	<b>6</b>
8	4.1	Assumptions, Modeling and Study Techniques .....	6
9	4.2	Study Results.....	8
10	4.3	Summary of Findings .....	8
11	<b>5.0</b>	<b>Appendix A: Load Stress Reliability Assessment Results .....</b>	<b>10</b>
12	<b>6.0</b>	<b>Appendix B: CAISO Export Reliability Assessment Results.....</b>	<b>17</b>

# 1.0 Background & Purpose

The purpose of this report is to summarize scenario assessments performed during WestConnect’s 2018-19 Regional Transmission Planning Process (“Planning Process”). The Planning Subcommittee (“PS”) developed this report to document the assumptions, study methods, and findings from the scenario assessments.

The [2018-19 WestConnect Regional Planning Study Plan](#) (“Study Plan”) was approved by the PMC on March 14, 2018. The Study Plan identifies the scope and schedule of activities to be conducted during the planning cycle. In addition to describing the Base Case planning assessments used to identify regional transmission needs, the Study Plan also describes information-only scenario studies that look at alternate but plausible futures. Scenarios represent futures or system conditions with resource, load, and public policy assumptions that are different in one or more ways than what is assumed in the Base Cases.

Members or stakeholders propose scenarios for consideration in the WestConnect planning process through an open submittal window, as outlined in the WestConnect Business Practice Manual. WestConnect held the open window from December 1, 2017 through January 5, 2018. Several proposed scenarios were received and subsequently reviewed by the PS during public meetings on January 19, 2018 and on February 13, 2018. During the meetings, the PS discussed the proposed scenarios, member feedback, and the number of scenarios that would be appropriate to study. These conversations led to the inclusion of two scenarios in the final Study Plan: a Load Stress scenario and a CAISO Export Stress scenario. Both scenarios are reliability assessments. The purpose of the Load Stress scenario is to test the robustness of the Base Transmission Plan against significant unforeseen load growth. The intent of the CAISO Export scenario is to evaluate the reliability of the WestConnect regional system during conditions in which physical power flows from the CAISO to WestConnect during CAISO overgeneration conditions.

# 2.0 Study Scope

The PS finalized the study scopes and developed the models required to complete the two scenario assessments. The table below summarizes each scenario and the core questions that the studies were designed to investigate.

**Table 1: Scenario Case Descriptions & Core Questions**






Scenario	Description of Case	Core Questions to Investigate
Load Stress	The WestConnect-approved 2028 Heavy Summer Base Case conforming loads were scaled for each TOLSO based on feedback received during the scenario development process and the generation-load gap was filled with existing generator capacity not already dispatched in the Base Case. In one area,	How robust is the Base Transmission Plan when peak load is higher than expected?

Scenario	Description of Case	Core Questions to Investigate
	renewable capacity was added and dispatched to meet the load increase.	
CAISO Export	<p>Using the WestConnect-approved 2028 Production Cost Model (“PCM”), a power flow snapshot was developed based on system conditions identified for Hour 15 on June 18<sup>th</sup>.</p> <p>This hour was selected by the PS during the <a href="#">January 15, 2019, meeting</a> as a system condition representative of high CAISO export to WestConnect. The CAISO export to WestConnect was approximately 6,280 MW during that hour.<sup>1</sup></p>	During high export conditions from the CAISO to WestConnect, how reliable is the WestConnect regional transmission system?

1 The PS decided to perform both steady-state and transient stability contingency analysis on the  
2 scenarios. These assessments were performed using reliability standards adopted by the North  
3 American Electric Reliability Corporation [TPL-001-4 Table 1](#) (P0 and P1) and [TPL-001-WECC-CRT-3.1](#)  
4 (Transmission System Planning Performance WECC Regional Criterion), and supplemented with any  
5 more stringent Transmission Owner with Load Serving Obligations (“TOLSO”) planning criteria based  
6 on TOLSO member feedback.

7 Contingency definitions for the steady-state contingency analysis were limited to N-1 contingencies for  
8 elements 230kV and above, generator step-up (“GSU”) transformers for generation with at least 200 MW  
9 capacity, and member-requested N-2 contingencies. All bulk electric system (BES) branches and buses  
10 in the WECC model were monitored with violation reports filtered to exclude branch flows that  
11 increased less than 1% and voltage decline less than 0.5%.

12 The following contingencies were evaluated in the transient stability simulations for both scenario Base  
13 Cases:

- 14 
- 15 
- 16 
- 17 
- 18 

---

<sup>1</sup> The CAISO Export to WestConnect interface was defined using all monitored “seam” branches between the CAISO and WestConnect Load Areas in the PCM. The flow on unmonitored and non-BES “seam” branches was not included in the interface definition.



	<b>2028 Heavy Summer Base Case</b>	<b>2028 Load Stress Scenario</b>	<b>Change</b>
	Wind/Solar: 5,637 Other: 1,994 Total: 67,712	Wind/Solar: 6,350 Other: 2,233 Total: 71,200	
<b>Transmission</b>	2018-19 Base Transmission Plan		No change

1

2 After case development was completed, the reliability assessment described in Section 2.0 was  
3 performed.

4 **3.2 Study Results**

5 Results from the assessment are provided in Appendix A. The results include 15 voltage issues on multi-  
6 owner systems. The multi-owner issues that were identified were geographically isolated issues. None  
7 of the multi-owner issues indicate deficiencies in the Base Transmission Plan. There were single-owner  
8 system issues, all of which the PS determined to be local issues and not regional in nature.

9 **3.3 Summary of Findings**

10 The Load Stress scenario did not materially impact regional-level flows. Average branch loading  
11 increased by roughly 1% when compared to the 2028 Heavy Summer Case. Contingency analysis  
12 identified few multi-owner voltage issues. These multi-owner issues are informational, radial in nature,  
13 and do not indicate deficiencies in the Base Transmission Plan. Therefore, the study results indicate that  
14 the Base Transmission Plan is sufficiently robust under higher than expected load conditions.

15 **4.0 CAISO Export Stress Scenario**

16 **4.1 Assumptions, Modeling and Study Techniques**

17 The CAISO Export Stress scenario tests the reliability of the WestConnect regional system under a  
18 condition in which power flows from the CAISO region into WestConnect. Today and historically, net  
19 flow is almost always from WestConnect into the CAISO. This is especially true on the major interfaces  
20 between California and Arizona, including Path 46 (West of River) and Path 49 (East of River), which  
21 flow in the east-to-west direction. As the CAISO adds more solar onto its system, certain conditions  
22 cause the CAISO system to have more generation than it needs, particularly in light-load conditions in  
23 the spring and fall. This creates the opportunity for economic (transactional) exports out of the CAISO  
24 into WestConnect, as well as physical exports of power (i.e., actual power flow, which are different than  
25 energy transactions).

26 The CAISO Export Stress scenario was based on conditions observed in the WestConnect 2028 Base Case  
27 economic model. The modeling results were filtered for hours in which there were power flows from the


1 CAISO into WestConnect. In total, the export condition was observed in 13% of the hours in the study  
 2 2028 year. The PS focused on a review of hours in which both (1) exports from the CAISO to  
 3 WestConnect are high, and (2) flows west-to-east across Path 49 and Path 46 are high. The following  
 4 table identifies the condition selected by the PS for study: Hour 15 of June 18<sup>th</sup>. During this condition,  
 5 flows from the CAISO to WestConnect are 6,284 MW and flows on Path 46 and Path 49 are in the west-  
 6 to-east direction at 4,231 MW and 5,463 MW, respectively.<sup>3</sup>

7 **Table 3: June 18<sup>th</sup> Hour 15 Flows from the CAISO to WestConnect**

		Flow (MW)		
Date	Hour	P46 [E->W]	P49 [E->W]	CAISO Export to WC (Approx.)
6/18/2028	15	-4,231	-5,463	6,284

8 The simulated WestConnect and the CAISO load levels and generation dispatch are summarized in the  
 9 figures below. The gap between the load and the top of the generation stack represents imports into the  
 10 given region. When the stack is above the load level, this represents exports.

11 **Figure 1: WestConnect & the CAISO Load & Generation During Selected CAISO Export on June 18<sup>th</sup> Hour 15**



12 The transmission topology did not change from the Base Case assessments and reflects the 2018-19  
 13 Base Transmission Plan additions. The seed case was the approved WestConnect 2028 Heavy Summer  
 14 Base Case. The load, imports, and generator dispatch assumptions are provided below.

<sup>3</sup> Not that the interface between the CAISO and WestConnect was defined as all monitored seam branches between the CAISO and WestConnect Load Areas. This means that branches between WestConnect loads in California and the CAISO were included in the interface. Non-bulk system branches and unmonitored branches were not included in the seam.

1

**Table 4: CAISO Export Scenario Assumptions for WestConnect Region**

	<b>2028 Heavy Summer Base Case</b>	<b>2028 CAISO Export Scenario</b>	<b>Delta</b>
<b>Load (MW)</b>	65,274 <sup>4</sup>	35,872 <sup>5</sup>	Decreased 54.96%
<b>Import/Export (MW)</b>	Export: 2,438	Import: 7,273	Switch from net export to net import (354.67% change)
<b>Generation Dispatch (MW)</b>	Thermal: 53,179 Hydro: 6,902 Wind/Solar: 5,637 Other: 1,994 Total: 67,712	Thermal: 18,621 Hydro: 3,187 Wind/Solar: 6,120 Other: 671 Total: 28,599	Decreased 42.24%
<b>Transmission</b>	2018-19 Base Transmission Plan		No change

2

3 After initial case development was completed, the reliability assessment described in Section 2.0 was  
4 performed.

## 5 **4.2 Study Results**

6 Results from the assessment are provided in Appendix B. The results include 6 branch overloads and 9  
7 voltage issues on multi-owner transmission. The thermal branch overloads were located in the Colorado  
8 and Wyoming area. Single-system issues were reviewed and the PS determined that these single-system  
9 issues were not regional in nature.

## 10 **4.3 Summary of Findings**

11 The case development was successful in that a CAISO export condition was identified in the  
12 WestConnect 2028 Economic Base Case, and this condition was replicated in reliability models in terms  
13 of load, generation dispatch, and system flows. Reliability analysis of the condition identified several  
14 multi-owner voltage issues that can be easily addressed through system adjustments. The analysis also  
15 identified a few thermal overloads in the Colorado area, but these issues are remote from the CAISO-  
16 WestConnect interface(s) and are caused by flows occurring in entirely new directions than what is

---

<sup>4</sup> Represents the system coincident peak for a heavy summer conditions between the hours of 1500 to 1700 MDT during the months of June – August.

<sup>5</sup> Note that this load forecast is based on 1-in-2 load forecasts contained in the production cost model. The 2028 Heavy Summer Base case is based on 1-in-10 load forecasts. This discrepancy accounts for a portion of the load differential between the two cases.



1 observed historically. At a high-level, the scenario does not significantly stress the regional transmission  
2 system beyond levels identified in the Base Cases and the regional system is robust during CAISO export  
3 conditions.

# 5.0 Appendix A: Load Stress Reliability Assessment Results

Issues are related to facility loadings or voltage. Transmission elements are typically rated in Amps, transformers in MVA, and voltage in per-unit (pu).

Table 5: Load Stress Reliability Assessment Contingency Analysis

Base Case PF	Disturbance(s) [Multiple if affected elements were the same]	Affected Element					Comment
		Owner/ Operator	Affected Element	Value under (Worst) Disturbance	Limit	Issue	
Load Stress	PNM's P1 (██████)	PNM	MONTANOT - CLAREMNT 115kV Line #1	██████	██████	Line Overload	PNM: PNM has plans to uprate this line segment in the 10-year planning horizon.
		PNM	PRAGER - MONTANOT 115kV Line #1	██████	██████	Line Overload	PNM: PNM has plans to uprate this line segment in the 10-year planning horizon.
Load Stress	APS's P1 (██████)	APS	CACTUS - OCO N 230kV Line #1	██████	██████	Line Overload	APS: APS has conceptual projects identified to address this overload
		APS	OCO C - OCO N 230kV Line #1	██████	██████	Line Overload	APS: APS has conceptual projects identified to address this overload
Load Stress	SRP's P1 (██████)	SRP	MESQUIT1 500/230kV Transformer #1	██████	██████	Transformer Overload	SRP: ██████ mitigated by ██████.
Load Stress	SRP's P1 (██████)	SRP	MESQUIT1 500/230kV Transformer #1	██████	██████	Transformer Overload	
Load Stress	SRP's P1 (██████)	SRP	MESQUIT2 500/230kV Transformer #2	██████	██████	Transformer Overload	

Base Case PF	Disturbance(s) [Multiple if affected elements were the same]	Affected Element				Comment	
		Owner/ Operator	Affected Element	Value under (Worst) Disturbance	Limit		Issue
Load Stress	SRP's P1 (████)	SRP	MESQUIT2 500/230kV Transformer #2	████	████	Transformer Overload	SRP: █████ mitigated by █████.
Load Stress	SRP's P1 (████)	SRP	PAPAGOBT - KYR-EAST 230kV Line #1	████	████	Line Overload	SRP: SRP's latest TPL assessment says that we will upgrade the line, but since this is far into the future the mitigation has not been fully vetted. If we upgrade everything (conductor, line drops, crossbay) the new ratings go up to █████ continuous and █████ emergency.
Load Stress	NVE's P1 (████)	NVE	MEAD N - ARDEN 230kV Line #1	████	████	Line Overload	NVE: The rating is limited by █████, which is to be replaced by WALC in 2019; after that rating will be █████ (conductor) that would mitigate this overload
Load Stress	NVE's P1 (████)	NVE	MEAD N - ARDEN 230kV Line #1	████	████	Line Overload	NVE: same as above
Load Stress	NVE's P1 (████)	NVE	TOLSON 230/138kV Transformer #1	████	████	Transformer Overload	NVE: Magnolia 230/138 XF #2 (in-service 2020), will mitigate; also can be mitigated by █████
Load Stress	LADWP's P1 (████)	LADWP	VELASCO - HAY N 230kV Line #1	████	████	Line Overload	LADWP: Mitigated by █████.
Load Stress	LADWP's P1 (████)	LADWP	TOLHOL11 - HOLYWD_E 230kV Line #1	████	████	Line Overload	LADWP: Mitigated by █████.
Load Stress	CSU's P1 (████)	CSU	KELKER N - RD_NIXON 230kV Line #1	████	████	Line Overload	
Load Stress	AEPCO's P1 (████)	AEPCO	KARTCHNR 115kV Bus	████	████	Low Voltage	

Base Case PF	Disturbance(s) [Multiple if affected elements were the same]	Affected Element					Comment
		Owner/ Operator	Affected Element	Value under (Worst) Disturbance	Limit	Issue	
Load Stress	WAPA's P1 (████)	APS	GAVILNPK 230kV Bus	████	████	Low Voltage	
		WAPA	GAVLINWA 230kV Bus	████	████	Low Voltage	
Load Stress	LADWP's P1 (████)	LADWP	SYLMAR S 230kV Bus	████	████	Low Voltage	LADWP: Mitigated by █████.
		LADWP	WLMNTNLD 138kV Bus	████	████	Low Voltage	LADWP: Mitigated by █████.
		LADWP	SYLMAR1 230kV Bus	████	████	Low Voltage	LADWP: Mitigated by █████.
		LADWP	SYL PF BUS 1 230kV Bus	████	████	Low Voltage	LADWP: Mitigated by █████.
		LADWP	SYL PF BUS 2 230kV Bus	████	████	Low Voltage	LADWP: Mitigated by █████.
Load Stress	Multiple LADWP P1's (████)	LADWP	ROSAMOND 230kV Bus	████	████	Low Voltage	LADWP: Mitigated by █████.
		LADWP	SO_PPA_21SU B 230kV Bus	████	████	Low Voltage	LADWP: Mitigated by █████.
Load Stress	EPE's P1 (████)	EPE	CHAPARAL - ORO_GRAN 115kV Line #1	████	████	Line Overload	EPE: An expected line rating uprate for this line by Summer of 2020 will eliminate this issue.  TSGT: If TSGT saw a sudden increase in loads forecasted for this area, TSGT would plan for these issues. This issue does not appear in TSGT's 10-year TPL study.
		EPE	ALA_5 115kV Bus	████	████	Low Voltage	EPE & TSGT: This result is consistent with the Base Case. As load increases more voltage support is needed.
		EPE	AMRAD 115kV Bus	████	████	Low Voltage	EPE & TSGT: This result is consistent with the Base Case. As load increases more voltage support is needed.

Base Case PF	Disturbance(s) [Multiple if affected elements were the same]	Affected Element				Issue	Comment
		Owner/Operator	Affected Element	Value under (Worst) Disturbance	Limit		
		EPE	AMRAD 345kV Bus	████	████	Low Voltage	EPE & TSGT: This result is consistent with the Base Case. As load increases more voltage support is needed.
		EPE	HOLLOMAN 115kV Bus	████	████	Low Voltage	EPE & TSGT: This result is consistent with the Base Case. As load increases more voltage support is needed.
		EPE	LARGO 115kV Bus	████	████	Low Voltage	EPE & TSGT: This result is consistent with the Base Case. As load increases more voltage support is needed.
		EPE	MAR 115kV Bus	████	████	Low Voltage	EPE & TSGT: This result is consistent with the Base Case. As load increases more voltage support is needed.
		EPE	WHITE_SA 115kV Bus	████	████	Low Voltage	EPE & TSGT: This result is consistent with the Base Case. As load increases more voltage support is needed.
		TSGT	ALAMOGPG 115kV Bus	████	████	Low Voltage	EPE, PNM & TSGT: This result is consistent with the Base Case. As load increases more voltage support is needed.
		TSGT	BLAZER_T 115kV Bus	████	████	Low Voltage	EPE, PNM & TSGT: This result is consistent with the Base Case. As load increases more voltage support is needed.
		TSGT	C_CANYON 115kV Bus	████	████	Low Voltage	EPE, PNM & TSGT: This result is consistent with the Base Case. As load increases more voltage support is needed.

Base Case PF	Disturbance(s) [Multiple if affected elements were the same]	Affected Element				Issue	Comment
		Owner/ Operator	Affected Element	Value under (Worst) Disturbance	Limit		
		PNM	ALAMOGCP 115kV Bus	████	████	Low Voltage	EPE, PNM, & TSGT: This result is consistent with the Base Case. As load increases more voltage support is needed.
		PNM	GAVILAN 115kV Bus	████	████	Low Voltage	EPE, PNM & TSGT: This result is consistent with the Base Case. As load increases more voltage support is needed.
		PNM	RUIDOSO 115kV Bus	████	████	Low Voltage	EPE, PNM & TSGT: This result is consistent with the Base Case. As load increases more voltage support is needed.
		PNM	TULAROSA 115kV Bus	████	████	Low Voltage	EPE, PNM & TSGT: This result is consistent with the Base Case. As load increases more voltage support is needed.
		EPE	AMRAD 345kV Bus	████	████	High % V Decrease	EPE & TSGT: This result is consistent with the Base Case. As load increases more voltage support is needed.
		EPE	AMRAD_B 345kV Bus	████	████	High % V Decrease	EPE & TSGT: This result is consistent with the Base Case. As load increases more voltage support is needed.
		EPE	ALA_5 115kV Bus	████	████	High % V Decrease	EPE & TSGT: This result is consistent with the Base Case. As load increases more voltage support is needed.

Base Case PF	Disturbance(s) [Multiple if affected elements were the same]	Affected Element				Comment	
		Owner/ Operator	Affected Element	Value under (Worst) Disturbance	Limit		Issue
		EPE	HOLLOMAN 115kV Bus	████	████	High % V Decrease	EPE & TSGT: This result is consistent with the Base Case. As load increases more voltage support is needed.
		EPE	MAR 115kV Bus	████	████	High % V Decrease	EPE & TSGT: This result is consistent with the Base Case. As load increases more voltage support is needed.
		EPE	WHITE_SA 115kV Bus	████	████	High % V Decrease	EPE & TSGT: This result is consistent with the Base Case. As load increases more voltage support is needed.
		TSGT	BLAZER_T 115kV Bus	████	████	High % V Decrease	EPE, PNM & TSGT: This result is consistent with the Base Case. As load increases more voltage support is needed.
		TSGT	C_CANYON 115kV Bus	████	████	High % V Decrease	EPE, PNM & TSGT: This result is consistent with the Base Case. As load increases more voltage support is needed.
		TSGT	JARILLA1 115kV Bus	████	████	High % V Decrease	EPE & TSGT: This result is consistent with the Base Case. As load increases more voltage support is needed.
		PNM	ALAMOGCP 115kV Bus	████	████	High % V Decrease	EPE, PNM & TSGT: This result is consistent with the Base Case. As load increases more voltage support is needed.

Base Case PF	Disturbance(s) [Multiple if affected elements were the same]	Affected Element				Comment	
		Owner/ Operator	Affected Element	Value under (Worst) Disturbance	Limit		Issue
		PNM	GAVILAN 115kV Bus	████	████	High % V Decrease	EPE, PNM & TSGT: This result is consistent with the Base Case. As load increases more voltage support is needed.
		PNM	RUIDOSO 115kV Bus	████	████	High % V Decrease	EPE, PNM & TSGT: This result is consistent with the Base Case. As load increases more voltage support is needed.
		PNM	TULAROSA 115kV Bus	████	████	High % V Decrease	EPE, PNM & TSGT: This result is consistent with the Base Case. As load increases more voltage support is needed.

1



# 6.0 Appendix B: CAISO Export Reliability Assessment Results

Issues are related to facility loadings or voltage. Transmission elements are typically rated in Amps, transformers in MVA, and voltage in per-unit (pu).

Table 6: CAISO Export Reliability Assessment Contingency Analysis

Base Case PF	Disturbance(s) [Multiple if affected elements were the same]	Affected Element					Comment
		Owner/ Operator	Affected Element	Value under (Worst) Disturbance	Limit	Issue	
CAISO Export	WAPA's P1 (████)	WAPA	ROGSWAPA - PINPK 230kV Line #1	████	████	Line Overload	
	WAPA's P1 (████)	WAPA	ROGSWAPA - PINPK 230kV Line #2	████	████	Line Overload	
	PSCO's P1 (████)	BEPC	DAVEJOHN - SAWMILLCK 230kV Line #1	████	████	Line Overload	PSCO: Results are due to loss of █████ in power flow model, which does not accurately reflect governor action of other generation units. BEPC: The noted overload on the LRS-Sawmill Crk-DJ 230 kV line for the n-1 outage of █████ is due to the additional wind that PacifiCorp has added around DJ. The overload would be mitigated pre-contingent via the WECC Unscheduled Flow Mitigation plan.
			SAWMILLCK - LAR.RIVR 230kV Line #1	████	████	Line Overload	
	BEPC's P1 (████)	BEPC	DAVEJOHN - SAWMILLCK 230kV Line #1	████	████	Line Overload	BEPC: The noted overload on the LRS-Sawmill Crk-DJ 230 kV line for the n-1 outage of █████ is due to the additional wind that PacifiCorp has added around DJ. The overload would be mitigated pre-contingent via the WECC Unscheduled Flow Mitigation plan.

Base Case PF	Disturbance(s) [Multiple if affected elements were the same]	Affected Element					Comment
		Owner/ Operator	Affected Element	Value under (Worst) Disturbance	Limit	Issue	
CAISO Export	BEPC's P1 (██████)	BEPC	DAVEJOHN - SAWMILLCK 230kV Line #1	██████	██████	Line Overload	BEPC: The noted overload on the LRS-Sawmill Crk-DJ 230 kV line for the n-1 outage of ██████ is due to the additional wind that PacifiCorp has added around DJ. The overload would be mitigated pre-contingent via the WECC Unscheduled Flow Mitigation plan.
			SAWMILLCK - LAR.RIVR 230kV Line #1	██████	██████	Line Overload	BEPC: The noted overload on the LRS-Sawmill Crk-DJ 230 kV line for the n-1 outage of ██████ is due to the additional wind that PacifiCorp has added around DJ. The overload would be mitigated pre-contingent via the WECC Unscheduled Flow Mitigation plan.
	WAPA's P1 (██████)	DG&T	RANGELY - CALAMRDG 138kV Line #1	██████	██████	Line Overload	PSCo & TSGT: CAISO Export round trip resulted in unprecedented west-east flows through Colorado. The WECC TOT1A path limit is not defined in this direction due to the unrealistic nature of these flows. Additional local studies may be needed should the flows in the scenario occur in Base Case studies.
		TSGT	MEEKER - W.RV.CTY 138kV Line #1	██████	██████	Line Overload	PSCo & TSGT: CAISO Export round trip resulted in unprecedented west-east flows through Colorado. The WECC TOT1A path limit is not defined in this direction due to the unrealistic nature of these flows. Additional local studies may be needed should the flows in the scenario occur in Base Case studies.
			W.RV.CTY - CALAMRDG 138kV Line #1	██████	██████	Line Overload	PSCo & TSGT: CAISO Export round trip resulted in unprecedented west-east flows through Colorado. The WECC TOT1A path limit is not defined in this direction due to the unrealistic nature of these flows. Additional local studies may be needed should the flows in the scenario occur in Base Case studies.
		LADWP	INT PF BUS 2 345kV Bus	██████	██████	High Voltage	

Base Case PF	Disturbance(s) [Multiple if affected elements were the same]	Affected Element					Comment
		Owner/ Operator	Affected Element	Value under (Worst) Disturbance	Limit	Issue	
CAISO Export	PSCO's P1 (████)	PSCO	HOPKINS - BASALT 115kV Line #1	████	████	Line Overload	PSCo: CAISO Export round trip resulted in unprecedented west-east flows through Colorado. Additional local studies may be needed should the flows in the scenario occur in Base Case studies.
	PSCO's P1 (████)	PSCO	HOPKINS - BASALT 115kV Line #1	████	████	Line Overload	PSCo: CAISO Export round trip resulted in unprecedented west-east flows through Colorado. Additional local studies may be needed should the scenario become plausible.
	WAPA's P1 (████)	PSCO	PONCHA - SMELTER 115kV Line #1	████	████	Line Overload	PSCo: CAISO Export round trip resulted in unprecedented west-east flows through Colorado. Additional local studies may be needed should the flows in the scenario occur in Base Case studies.
	WAPA's P1 (████)	WAPA	SANJN PS - WATRFLW 345kV PST #1	████	████	PST Overload	WACM: Overloads on Phase Shifting Transformers. Change angles on transformers at █████ and at █████.
	WAPA's P1 (████)	WAPA	SANJN PS - WATRFLW 345kV PST #2	████	████	PST Overload	WACM: Overloads on Phase Shifting Transformers. Change angles on transformers at █████ and at █████.
	SRP's P1 (████)	SRP	PERKINS 500kV Bus	████	████	High Voltage	SRP: The line reactor at █████ is off in the base case. This reactor is normally in-service. Modeling the line reactor as in-service mitigates the high voltage concern.

Base Case PF	Disturbance(s) [Multiple if affected elements were the same]	Affected Element					Comment	
		Owner/ Operator	Affected Element	Value under (Worst) Disturbance	Limit	Issue		
CAISO Export	IPA's P1 (██████)	IPA	INTERMT 345kV Bus	██████	██████	High Voltage	LADWP: Mitigated by ██████.	
			INTERMTX 345kV Bus	██████	██████	High Voltage		
			INTERMTY 345kV Bus	██████	██████	High Voltage		
		LADWP	INT PF BUS 1 345kV Bus	██████	██████	High Voltage		
			INT PF BUS 2 345kV Bus	██████	██████	High Voltage		
			INT PF BUS 3 345kV Bus	██████	██████	High Voltage		
			INT PF BUS 4 345kV Bus	██████	██████	High Voltage		
	SOL2SUB 345kV Bus	██████	██████	High Voltage				
	SOL1SUB 345kV Bus	██████	██████	High Voltage				
	LADWP's P1 (██████)	LADWP	MARKETPL 500kV Bus	██████	██████	High Voltage		LADWP: Mitigated by ██████.
			MKTPSVC 500kV Bus	██████	██████	High Voltage		
			COPPMTN3 500kV Bus	██████	██████	High Voltage		
	LADWP's P1 (██████)	LADWP	INT PF BUS 2 345kV Bus	██████	██████	High Voltage		LADWP: This element is a ██████. This is not a credible contingency.
SOL1SUB 345kV Bus			██████	██████	High Voltage	LADWP: This element is a ██████. This is not a credible contingency.		